



REQUIREMENTS

1. NO TAPS, TEES OR CONNECTIONS OF ANY KIND ARE PERMITTED BETWEEN THE WATER METER AND RECEIVING VESSEL.
2. THE SERVICE PIPE BETWEEN THE WATER METER AND RECEIVING VESSEL MUST BE VISIBLE ABOVE FINISHED GRADE FROM 12 INCHES BEHIND PROPERTY LINE TO THE RECEIVING VESSEL.
3. PROTECTION FROM FREEZE DAMAGE MAY BE NECESSARY IN EXPOSED AREAS.
4. FOR PERMANENT OR MOBILE VEHICLE USE (ie: PEST CONTROL TRUCKS)