




TWO LANE STREET



MULTI-LANE STREET




TWO LANE STREET
AT INTERSECTION




NOTE: * -APPLIES WHEN FH IS LOCATED
WITHIN 50' OF INTERSECTION.


FOUR LANE STREET
WITH TURN LANE AT
INTERSECTION



MULTI-LANE STREET
WITH TURN LANE



FREEWAYS AND
EXPRESSWAYS



LEGEND

- Blue Pavement Marker, STIMSONITE 88 B1-DIRECTIONAL, or a EQUIVALENT.
- ⊙ Fire Hydrant

NOTES

1. REFLECTIVE FIRE HYDRANT MARKERS SHALL BE INSTALLED AT THE FIRE DEPARTMENTS DIRECTIONS.
2. MARKERS SHOULD BE PLACED IN LINE WITH HYDRANT AND ABOUT 6" OFF CENTER ON HYDRANT SIDE AND NOT IN A LOW SPOT.
3. MARKERS SHALL BE BLUE "STIMSONITE 88" BI-DIRECTIONAL, OR EQUIVALENT APPROVED BY THE FIRE CHIEF.
4. WHEN A FIRE HYDRANT IS WITHIN 50' OF A CORNER, TWO MARKERS SHOULD BE PLACED ON EACH INTERSECTING STREET.